


Reporting Year 2012



There When You Need Us

We are once again proud to present our annual water quality report covering all testing performed between January 1 and December 31, 2012. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal standards. We are striving to construct a new well and storage tank to assure water supply. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all our water users.

Please remember that we are always available to assist you should you ever have any questions or concerns about your water.

Community Participation

You are invited to attend and participate in our public forum and voice your concerns about your drinking water. We meet the 1st Tuesday of each month beginning at 7 p.m. at the District business office located at 8319 Lander Avenue, Hilmar, CA 95324. Agendas for meetings are posted at the office and online at www.hilmarcwd.org.

Source Water Assessment

A Source Water Assessment Plan (SWAP) is now available at our office. This plan is an assessment of the delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources.

According to the Source Water Assessment Plan, our water is considered most vulnerable to the effects of agricultural drainage, grazing, lagoon/liquid wastes, animal operations, and septic systems. A copy of the complete assessment is available for review at the District's office during business hours.

Substances That Could Be in Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (U.S. EPA) and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

Inorganic Contaminants, such as salts and metals, that can be naturally occurring or can result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and which can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems;

Radioactive Contaminants, that can be naturally occurring or can be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Where Does My Water Come From?

Your water comes from two District owned wells located one mile east of town. These wells average 330 feet in depth and have a sanitary seal for the first 150 feet of the well column. In 2012, these wells provided 412 million gallons of water to the District's customers. Plans are now underway to construct and develop a new third well to help meet the demand for water.

Information on the Internet

The U.S. EPA Office of Water (www.epa. gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation, and public health. Also, the Division of Drinking Water and Environmental Management has a Web site (www.cdph.ca.gov/ certlic/drinkingwater/Pages/default.aspx) that provides complete and current information on water issues in California, including valuable information about our watershed.

QUESTIONS?

For more information about this report, or for any questions relating to your drinking water, please call Dale Wickstrom at (209) 632-3522.

Important Health Information

While your drinking water meets the Federal and State standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/ AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or http://water.epa.gov/drink/hotline.

Regulating Arsenic

A rsenic contamination of drinking water sources may result from either natural or human activities. Volcanic activity, erosion of rocks and minerals, and forest fires are natural sources that can release arsenic into the environment. Although about 90 percent of the arsenic used by industry is for wood preservative purposes, it is also used in paints, drugs, dyes, soaps, metals, and semiconductors. Agricultural applications, mining, and smelting also contribute to arsenic releases. Arsenic is usually found in the environment combined with other elements such as oxygen, chlorine, and sulfur (inorganic arsenic); or combined with carbon and hydrogen (organic arsenic). Organic forms are usually less harmful than inorganic forms.

Low levels of arsenic are naturally present in water -- about 2 parts arsenic per billion parts of water (ppb). Thus, you normally take in small amounts of arsenic in the water you drink. Some areas of the country have unusually high natural levels of arsenic in rock, which can lead to unusually high levels of arsenic in water.

In January 2001, the U.S. EPA lowered the arsenic Maximum Contaminant Level (MCL) from 50 to 10 ppb in response to new and compelling research linking high arsenic levels in drinking water with certain forms of cancer. All water utilities were required to implement this new MCL in January 2006.

Removing arsenic from drinking water is a costly procedure but well worth the expenditure considering the health benefits. For a more complete discussion, visit the U.S. EPA's arsenic Web site at http://water.epa.gov/lawsregs/rulesregs/sdwa/arsenic/index.cfm.

Water Main Flushing

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, water quality can deteriorate in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen and disinfectant levels, and an acceptable taste and smell.

During flushing operations in your neighborhood, some short-term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use and avoid using hot water, to prevent sediment accumulation in your hot water tank.

Please contact us if you have any questions or if you would like more information on our water main flushing schedule.



You may not be aware of it, but every time you pour fat, oil, or grease (FOG) down your sink (e.g., bacon grease), you are contributing to a costly problem in the sewer collection system. FOG coats the inner walls of the

plumbing in your house as well as the walls of underground piping throughout the community. Over time, these greasy materials build up and form blockages in pipes, which can lead to wastewater backing up into parks, yards, streets, and storm drains. These backups allow FOG to contaminate local waters, including drinking water. Exposure to untreated wastewater is a public health hazard. FOG discharged into septic systems and drain fields can also cause malfunctions, resulting in more frequent tank pump-outs and other expenses.

Communities spend billions of dollars every year to unplug or replace grease-blocked pipes, repair pump stations, and clean up costly and illegal wastewater spills. Here are some tips that you and your family can follow to help maintain a well-run system now and in the future:

NEVER:

- Pour fats, oil, or grease down the house or storm drains.
- Dispose of food scraps by flushing them.

• Use the toilet as a waste basket.

ALWAYS:

- Scrape and collect fat, oil, and grease into a waste container such as an empty coffee can, and dispose of it with your garbage.
- Place food scraps in waste containers or garbage bags for disposal with solid wastes.
- Place a wastebasket in each bathroom for solid wastes like disposable diapers, creams and lotions, and personal hygiene products including nonbiodegradable wipes.

Factor Fiction

Water treatment began as a way to remove disease-causing agents. (Fiction: It was only in the 1950s that scientists began to suspect that water might carry diseases. Although earlier treatment of water could make the water safer, it was mainly done merely to improve the taste, smell, or appearance of the water.)

About half of the world's water supply is available for drinking. (Fiction: If all the world's water were fit into a gallon jug, the fresh water available for us to use would equal only about one tablespoon.)

Due to its unique nature, water boils at the same temperature anywhere on the planet. (Fiction: At sea level, water boils at 212 degrees Fahrenheit, but on top of Mt. Everest, water boils at 154 degrees.)

Water regulates the temperature of the Earth. (Fact: As in the human body, the water in our oceans, lakes, and streams plays a major role in regulating planetary temperatures.)

The Mississippi River is longer than the Amazon River. (Fiction: At 3,902 miles the Mississippi River is not as long as the Amazon River, which flows for 4,000 miles.)

Forty trillion gallons of water a day are carried in the atmosphere across the United States. (*Fact: Forty percent of the atmosphere's moisture content falls as precipitation each day.*)

Sampling Results

uring the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The tables below show only those contaminants that were detected in the water. The state requires us to monitor for certain substances less often than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTAN	CES						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG) [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Arsenic ¹ (ppb)	2012	10	0.004	9.1	4.1–12.3	No	Erosion of natural deposits; runoff from orchards; glass and
							electronics production wastes
Chlorine (ppm)	2012	[4.0 (as	[4 (as Cl2)]	0.58	0.42-0.72	No	Drinking water disinfectant added for treatment
••		Cl2)]					
Nitrate [as nitrate] (ppm)	2012	45	45	10.8	6.4–17	No	Runoff and leaching from fertilizer use; leaching from septic
							tanks and sewage; erosion of natural deposits

Tap water samples were collected for lead and copper analyses from sample sites throughout the community²

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	PHG (MCLG)	AMOUNT DETECTED (90TH%TILE)	SITES ABOVE AL/ TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2010	1.3	0.3	0.014	0/20	No	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb)	2010	15	0.2	4	0/20	No	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits

UNREGULATED SUBSTANCES								
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE				
Sodium ³ (ppm)	2011	50	46–54	Erosion of natural deposits				
Total Hardness ³ (ppm)	2011	70	69–70	Naturally occurring				
Trichloropropane [1,2,3-TCP] ^₄ (ppb)	2012	ND	NA	Chemical fumigants				

levels to exceed the MCL. ²The reported results represent the most recent round of sample monitoring. The District is scheduled to test again in 2013. ³The reported results represent the most recent round of sample monitoring. ⁴Some people who drink water containing 1,2,3-trichloropropane in excess of the Public Health Goal or Notification Level over many years may have an increased risk of getting cancer, based on studies in laboratory animals. Monitoring of the

District's wells in 2012 showed levels to be below the Notification Level of 0.005 ug/L (ppb). A Public Health Goal for TCP is currently 0.0007 ppb.

Definitions

AL (Regulatory Action Level): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste, and appearance of drinking water.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. EPA.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

ND: Not detected or below detection limit.

NS: No standard.

PDWS (Primary Drinking Water Standard): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

PHG (Public Health Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California EPA.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).